



Government of Tripura  
Directorate of Fire & Emergency Services  
Tripura, Agartala.

Phone: 0381-2326451 Fax: 0381-2324826 Email: [dfreservice@tripura.gov.in](mailto:dfreservice@tripura.gov.in) Website: [www.fireservice.tripura.gov.in](http://www.fireservice.tripura.gov.in)

No. 3-8/TFES/2022/ 2138-40

Dated, Agartala, the 10<sup>th</sup> March, 2022.

To  
The Principal,  
Brilliant Stars School,  
East Dhajanagar, Gokulpur, Udaipur, Gomati Tripura.  
E-mail: [administrator@brilliantstarschool.org](mailto:administrator@brilliantstarschool.org). Mob: 9366459172.

Subject: - Issuance of Fire NOC.

Sir,

With reference to letter dated 31.01.2022, it is hereby certified that the building/premises as per description below has been inspected by the officer concerned of this department on 04.02.2022. In respect of implementation of Fire Safety measures, it was found that said building/establishment have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016. Therefore, the premises/building is issued Temporary NOC with effect from 09-3-22 for a period of 03 (three) months subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building/premises :- "Brilliant Stars School", East Dhajanagar, Gokulpur, Udaipur, Gomati Tripura.

Issued on 09-3-22 at Agartala.

N.B. Department is switching over offline issuance of NOC to online shortly. Therefore provisional / Temporary NOC is issued for a period of 03 (three) months. Thereafter, application to be submitted online ([www.edistrict.tripura.gov.in](http://www.edistrict.tripura.gov.in)) for Fire NOC.

Yours faithfully,

  
Joint Director,


Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:-

1. The Divisional Fire Officer, Gomati District, Udaipur, Tripura for favour of information.
2. The OC, Udaipur F&ES Station for information.



GOVERNMENT OF TRIPURA  
 DIRECTORATE OF FIRE & EMERGENCY SERVICES  
 AGARTALA, TRIPURA

Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website: www.fireservice.tripura.gov.in

Application Reference No: FSRTFES/2024/00063

Dated: 06/04/2024

**ACKNOWLEDGEMENT CUM MONEY RECEIPT**

**Applicant's Details**

<b>Name</b>	Vinod Kumar	<b>E-Mail</b>	principal@brilliantstarschool.org
<b>Mobile</b>	9612929146	<b>Police Station</b>	Radhakishorepur
<b>Building Address</b>	Near Netaji Maha Vidhyalaya Habitation, Dhajanagar Gram Panchayat, Tepania Block, Post Office Gekulpur S.O - 799114, Gomati District, Tripura.		

**Payment Details:**

GRN 24097A1286  
 CIN IGARCERYU4  
 Txn Date 06/04/2024  
 Amount 3000.00  
 Status Success

**Fees paid is non refundable**

For  
 Directorate of Fire & Emergency  
 Services

**Annexures Details**

Type of document(s)	Document(s) Attached
Other	Other
Power of Attorney/ Authorization Letter	Power of Attorney/ Authorization Letter
Existing Building Plans	Existing Building Plans
Drawings of the proposed fire protection arrangements	Drawings of the proposed fire protection arrangements

*[Signature]*  
 Manager  
 Brilliant Stars School  
 Udaipur, Gomati, Tripura.

*[Signature]*  
 18/04/24  
 Principal  
 Brilliant Stars School  
 Udaipur, Gomati, Tripura.